



SOUTH DAVIS METRO FIRE AGENCY

PEER REVIEW FOR FIRE PROTECTION SYSTEMS

In accordance with Section 104.7.2 of the International Fire Code, South Davis Metro will require a “technical opinion and report” (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation and/or modification of fire alarm and detection systems and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system.

Exceptions to required peer reviews:

- 1- Installation of fire hydrants and underground fire protection supply lines.
- 2- Pre-engineered kitchen hood suppression systems.
- 3- Installation or relocation of less than 20 sprinkler heads.
- 4- Installation or relocation of less than 5 alarm/notification appliances or less.

The following companies have been approved by the South Davis Metro Fire Agency as the design professionals from whom third party plan reviews will be accepted:

Protection Consultants Inc.

Bob Goodloe

1199 S. Main St #101
Centerville, Utah 84014
Office: 801-295-6070
Fax: 801-677-6070
Email: bob@pciut.com

West Coast Code Consultants, Inc.

Scott W. Adams

908 West Gordon Avenue – Suite #3
Layton, UT 84041
Mobile: 435-901-2891
Office: 385-237-3722
Email: scotta@wc-3.com
Submittals: permitdeskutah@wc-3.com

RDF Engineering & Design

Robert D. Fazzio, P.E.

3668 S. Eastwood Drive
SLC, Utah 84109
Office: 801-277-4933
Mobile: 801-556-3343
Email: rdfeng@comcast.net

Craig Blue, PE Inc.

Craig Blue, P.E.

1971 West 3300 South #A
West Valley City, Utah 84119
Office: 801-886-3473
Email: craig@cbluepe.com